



# EC-type examination certificate

Number **T10012** revision 0  
Project number 609878  
Page 1 of 1

Issued by NMI Certin B.V.  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands

Notified Body number 0122

In accordance with The "Metrologiewet" (Stb. 2006, 137) as Dutch implementation of Directive 2004/22/EC on measuring instruments (MID).

Manufacturer ABB Automation Technologies AB / Cewe-Control  
Brukslagarvägen 5  
SE-611 29 Nyköping  
Sweden

In respect of A model of a static **Active Electrical Energy Meter**

Type : FB.11. (DELTAsingle)

Characteristics Reference voltage : 230 V  
Reference current : 10 A  
Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network  
Accuracy class : A or B  
Mechanical environment class : M1  
Electromagnetic environment class : E2  
Temperature range : -40°C / +70°C

In the description number T10012 revision 0 further characteristics are described.

Valid until 15 February 2017

Description and documentation The instrument is described in the description number T10012 revision 0 and documented in the documentation folder T10012-1, appertaining to this EC-type examination certificate.

Dordrecht, 15 February 2007  
NMI Certin B.V.

Ing. C. Oosterman  
Manager Product Certification

