



CB TEST CERTIFICATE

Issued by: KEMA Quality B.V.

Registration date: 2003-07-09

Product: Circuit-breakers

Applicant: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 69123 Heidelberg Germany

Manufacturer: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 69123 Heidelberg Germany

Factory: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 69123 Heidelberg Germany

Rating and principal characteristics: - DC13 24 V - 2,0 A, 125 V - 0,55 A, 250 V - 0,27 A, 400 V, 0,1 A,
- AC15 240 V - 4 A, 400 V - 3 A, 500 V - 2 A, 690 V, 1 A, Ith/ Ithe 6 A, Ui 690 V.

Trade mark (if any): ABB

Model/Type reference: HK1-11, HK1-20, HK1-02, SK1-11, SK 1- 20, SK1- 02

Additional information: -

Sample of product tested to be in conformity with IEC: 60947-5-1(ed.2);am1;am2

Test Report Ref. No: 2024892.52

This CB Test Certificate is issued by the National Certification Body

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2003-07-08