



# Type Approval Certificate

Germanischer Lloyd

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 96 668 - 95 HH

Company ABB STOTZ-KONTAKT GmbH  
Eppelheimer Straße 82  
D-69123 Heidelberg

Product Description Manual motor starter

Type MS325, MS326 \*), MO325 \*\*)

Environmental Category C

Technical Data / Range of Application  
Rated current Ie: 0.1 up to 25 A  
Rated voltage Ue: 690 V AC/440 V DC  
Rated frequency: 40 up to 60 Hz  
Rated insulation voltage Ui: 690 V  
Utilization category: AC 3  
Rated short-circuit capacity at Ue: 380/400 - 500 - 690 V  
Type: Type: MS325-0.16 / MS325-1.6  
Ics: 100 - 100 - 100 kA  
Type: MS325-2.5 / MS325-4  
Ics: 100 - 40 - 10 kA  
Type: MS325-6.3 / MS325-9 / MS325-12.5 / MS325-16  
Ics: 100 - 30 - 3 kA  
Type: MS325-20 / MS325-25  
Ics: 50 - 20 - 2 kA  
\*) optional without phase failure protection  
\*\*) without thermal overload protection

Test Standard Regulations for the Performance of Type Tests (1993)  
IEC 60947-2(2002), IEC 60947-4-1(2000)

Documents Test report: ALPHA No. M15.94.01 (12.10.94), KEMA no. 274-93 (19.07.93), AQUA  
SIGNAL no. QTR F 17 (26.08.94), Declaration of conformity MO325(11.04.97),  
Declaration of conformity MO326 (21.09.98),  
Technical data sheet: ABB-Publication G SST 1001 93 L 0001

Remarks None

Valid until 2010-08-16

Page 1 of 1

File No. I.K.01

Hamburg, 2005-08-16

Type Approval Symbol



Germanischer Lloyd

*W. Voß*  
W. Voß

*J. Altmann*  
J. Altmann