

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 14 429 - 99 HH

Company ABB STOTZ-KONTAKT GmbH
Eppelheimer Straße 82
69123 Heidelberg, GERMANY

Product Description Circuit Breakers and Accessories

Type MS450, MS451, MO450, MS495, MS496, MS497, HK4, SK4, UA4, AA4, UA4-HK

Environmental Category C

Technical Data / Range of Application Rated current : 0,16-12 A / 0,16-25 A / 16-50 A / 16-100 A
Rated operational voltage Ue : 690 V AC
Rated operational impulse voltage Ui : 6 kV
Utilization category : A / AC-3
Short circuit capacity at 440 - 690 V
Icu: 50 up to 100 - 6 up to 100 kA
Ics: 25 up to 100 - 3 up to 100 kA

Setting currents : 0,11-12 A / 0,11-25 A / 11-50 A / 11-100 A
Setting ranges: 20 / 24 / 7 / 10
Accessories:
Auxiliary switch blocks: AC-15: 6 A / 230 V, DC-13: 0,25 A / 220V
AC-15: 3 A / 230 V, DC-13: 0,1 A / 220V
Signalling switches: AC-15: 6 A / 230 V, DC-13: 0,25 A / 220V
Auxiliary releases: 20,2 VA / 13 W at pick up / 7,2 VA / 2,4 W continuous duty

Test Standard Regulations for the Performance of Type Tests (2003)
IEC 60947-1 (1996-09), IEC 60947-2 (1995-12), IEC 60947-4-1 (1990-05)

Documents Test Report : No. 98340TQ03 sample 7 acc. SN_IACS (09/97, 02/98),

Remarks None

Valid until 2013-11-13

Page 1 of 1

File No. I.K.01

Hamburg, 2008-11-13

Type Approval Symbol



Germanischer Lloyd

Jürgen Wittburg

Jens Altmann