



DECLARATION OF CONFORMITY

We ABB France
Automation Product
Connection Devices
10 rue Ampère
69685 CHASSIEU Cedex
France

Declare that the product listed below :

Product : Terminal Blocks
Product Type: Screw Clamp Terminal Blocks

Déclarons que les produits de type M35/16 utilisant un shunt BJMI 16-2, possèdent une tension assignée d'emploi de 1000V selon la norme CEI 60947-1.

Declare that type M35/16 products using a shunt BJMI 16-2, have a rated voltage of 1000V according to IEC 60947-1.

Chassieu, 11 August 2010
Gaëlle Frier
Quality Development

A handwritten signature in black ink, appearing to be 'Gaëlle Frier', written over a horizontal line.